

**Контрольные измерения значений передаваемой мощности, нагрузок и уровней
напряжения на объектах электросетевого имущества ООО "Дорстрой"
Декабрь 2017 год**

Дата	Время	Мощность ТП (кВА)	№ ТП	Замер нагрузки (А)
18.12.2017	8:05	2х400	Аэронавигация	240
18.12.2017	8:00	2х630	1019	211
18.12.2017	8:10	250	1175	103
18.12.2017	8:05	2х630	947	191
18.12.2017	8:40	2х1000	1289	112
18.12.2017	8:50	2х630	1290	266
18.12.2017	8:45	2х1000	15	621
18.12.2017	8:55	2х1000	16	42
18.12.2017	9:10	2х1000	5	71
18.12.2017	9:15	2х1000	6	148
18.12.2017	9:30	2х1000	7	20
18.12.2017	9:45	2х400	10	420
18.12.2017	9:15	400	9 "Русичи"	6
18.12.2017	9:30	400	10"Русичи"	56
18.12.2017	10:00	2х1000	1088	320
18.12.2017	10:25	400	35	18
18.12.2017	9:25	2х630	36	264
18.12.2017	10:05	2х630	37	248
18.12.2017	10:15	2х630	38	198
18.12.2017	10:45	250	39	72
18.12.2017	11:20	160	40(1189)	20
18.12.2017	11:00	250	41(709)	38
18.12.2017	11:50	160	43	14
18.12.2017	13:10	250	44	106
18.12.2017	13:20	63	45	34
18.12.2017	12:55	400	46	201

18.12.2017	13:15	2x400	47(692)	150
18.12.2017	14:00	250	48(700)	140
18.12.2017	14:10	160	50(944)	80
18.12.2017	13:40	250	51(904)	103
18.12.2017	14:15	2x250	52	124
18.12.2017	14:35	400	54	264
18.12.2017	14:55	250	56(929)	80
18.12.2017	14:10	630	35T	281
18.12.2017	15:00	250	57(1067)	117
18.12.2017	15:15	630	60(1055)	207
18.12.2017	15:40	400	61(1267)	30
18.12.2017	15:00	160	62(1232)	51
18.12.2017	15:40	2x250	66(1220)	77
18.12.2017	16:55	400	67(992)	29
18.12.2017	16:30	400	68(1214)	114
18.12.2017	15:45	2x630	69(309)	434
18.12.2017	16:15	2x250	70(484)	130
18.12.2017	16:20	2x1000	73(1668)	193
18.12.2017	16:35	2x1000	74(1669)	9
18.12.2017	16:45	2x1000	75(1748)	195
18.12.2017	17:00	2x1000	76(1749)	161
18.12.2017	17:20	2x1200	77(1750)	100
18.12.2017	17:35	2x1000	78(1751)	4
18.12.2017	17:55	2x1200	79(1655)	227
18.12.2017	16:55	2x1200	80(30)	40
18.12.2017	17:00	63	81(1332)	0
18.12.2017	16:40	1000	82	3
18.12.2017	17:00	630	83	0
18.12.2017	17:20	630	84	0
18.12.2017	17:40		85	0
18.12.2017	18:05	400	86	0
19.12.2017	8:10	400	87(5055)	320
19.12.2017	8:20	250	88(2183)	122

19.12.2017	8:05	40	89(2066)	20
19.12.2017	8:00	250	90(2103)	11
19.12.2017	9:10	630	91(1373)	115
19.12.2017	9:15	630	92(1435)	12
19.12.2017	9:25	2x250	93(1369)	32
19.12.2017	9:30	250	95	24
19.12.2017	9:00	160	97(1349)	29
19.12.2017	9:55	400	98	184
19.12.2017	9:40	160	99(2043)	127
19.12.2017	10:10	250	100(2044)	68
19.12.2017	9:55	160	101(2045)	102
19.12.2017	10:25	250	102(2046)	257
19.12.2017	10:15	160	103(2047)	91
19.12.2017	10:55	250	104(819)	96
19.12.2017	10:30	250	105(938)	82
19.12.2017	11:00	160	106	119
19.12.2017	11:15	250	107	88
19.12.2017	11:35	160	108	174
19.12.2017	11:55	250	109	103
19.12.2017	13:00	250	110	135
19.12.2017	13:15	160	111	179
19.12.2017	13:25	100	112	78
19.12.2017	13:40	160	113	199
19.12.2017	13:55	100	114	177
19.12.2017	14:20	160	115	187
19.12.2017	14:50	250	116	111
19.12.2017	15:15	160	117	75
19.12.2017	15:45	63	118	48
19.12.2017	16:10	100	119	22
19.12.2017	10:55	400	120(716)	302
19.12.2017	11:40	160	121(1181)	122
19.12.2017	11:15	400	122(1316)	357
19.12.2017	16:50	100	124(914)	27

19.12.2017	11:20	100	125(2050)	68
19.12.2017	13:00	250	126(858)	179
19.12.2017	11:55	400	127(841)	27
19.12.2017	17:30	400	128(781)	114
19.12.2017	12:00	400	129(757)	192
19.12.2017	13:40	400	130(699)	245
19.12.2017	12:55	100	131(835)	52
19.12.2017	18:00	250	132(555)	59
19.12.2017	13:00	250	133(985)	60
19.12.2017	14:20	250	134(986)	165
19.12.2017	13:40	160	135(530)	114
19.12.2017	13:55	630	136(558)	565
19.12.2017	15:00	100	137(2001)	20
19.12.2017	14:10	160	138(605)	324
19.12.2017	14:30	630	139(552)	35
19.12.2017	15:40	400	140(554A)	103
19.12.2017	15:00	400	141(554)	368
19.12.2017	15:10	25	142(942)	6
19.12.2017	16:40	400	143(553)	0
19.12.2017	15:55	100	144(836)	112
19.12.2017	16:00	250	145(1477)	167
19.12.2017	17:30	2x630	146(23)	421
19.12.2017	16:45	400	147	0
19.12.2017	16:55	2x630	148	0
19.12.2017	18:15	250	149	17
19.12.2017	17:40	630	PTI №10	6
18.12.2017	8:30	400	42	173
18.12.2017	9:30	400	49(2025)	287
18.12.2017	10:10	1600	55	30
18.12.2017	11:15	630	71(1986)	86
18.12.2017	13:00	630	72(1960)	29
18.12.2017	14:10	100	96(2519)	48
18.12.2017	15:00	2x400	123(72)	36

18.12.2017	16:20	160	150(2149)	55
18.12.2017	17:05	630	151(1446)	48
18.12.2017	17:45	250	152(45)	7
18.12.2017	18:15	400	153(250)	53
		111MBT		15849